


 TRADE AND COMMERCE
 CANADA

SD-EA.187

STANDARDS DIVISION

OTTAWA, May 2, 1955.

TYPE APPROVAL

SANGAMO TYPE "S-3" SINGLE-PHASE WATTHOUR METERS
 AND OTHER SANGAMO METERS INCORPORATING S-3 ELEMENTS
 (FOR NAMEPLATE MARKINGS OF 120 VOLTS AND MULTIPLES THEREOF)

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "S-3" Single-phase, "S-3A" Single-phase, "S-3" Polyphase, "S-3S" Polyphase and "4L2" Polyphase Watthour Meters, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus: As previously approved except for the voltage rating. See the following approval circulars:-

<u>Meter Type</u>	<u>Description</u>	<u>Previous Approvals</u>
"S-3"	Single-phase (small base)	NRC-6, NRC-67, NRC-153, SD-EA.158
"S-3A"	Single-phase ('A' base)	SD-EA.8, SD-EA.158
"S-3"	Horizontal Polyphase also conversion type	NRC-13, NRC-137, SD-EA.80, SD-EA.158 SD-EA.25
"S-3S"	Horizontal Polyphase	SD-EA.89, SD-EA.158
"4L2"	Polyphase Demand-Energy	NRC-17, NRC-24, NRC-106, SD-EA.158

Description: These meters are identical to the same types approved under previous circulars (as above) except that the manufacturer is permitted to mark the nameplates with either 120-volt ratings and multiples thereof or the former 115 volts and multiples.

R. W. MacLean
 R. W. MacLean,
 Director,
 Standards Division.

E. F. Power
 E. F. Power,
 Assistant Director (E&G),
 Standards Division.

Ref: A-424B

