



TRADE AND COMMERCE  
CANADA

SD-EA.197

## STANDARDS DIVISION

OTTAWA, June 20, 1955.

TYPE APPROVAL

CANADIAN GENERAL ELECTRIC  
TYPE "PV-0" VOLTAGE TRANSFORMER

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "PV-0" Voltage Transformer, manufactured by the Canadian General Electric Company Limited, Toronto, Ontario.

## Rating of Apparatus:


Primary Voltage ..... 575, 460, 230 volts  
 Secondary Voltage ..... 115 volts  
 Accuracy Class ..... ASA 0.3X, 0.6Y  
 Voltage Class ..... 600 volts  
 Wire ..... 2  
 Phase ..... 1  
 Frequency ..... 60 cycles  
 Style ..... Dry Indoor.

Description: These voltage transformers are designed for indoor service and are of wound primary construction with single primary ratings. The manufacturer specifies high grade silicon steel used in the core. The entire core and coil assembly is impregnated with varnish to give high mechanical and electrical strength.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-454



SD-EA.197

CANADIAN GENERAL ELECTRIC  
TYPE "PV-O" VOLTAGE TRANSFORMER

