

SD-EA.207-A

(Supplementary to SD.EA.207)

TRADE AND COMMERCE

STANDARDS DIVISION

OTTAWA. Merch 5. 1956.

TYPE APPROVAL

CANADIAN GENERAL ELECTRIC TYPE "CS-15" CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "CS-15" Current Transformers, manufactured by the Canadian General Electric Company Limited, Toronto, Ontario.

Rating of Apparatus:

Secondary Current 5 amperes

Accuracy Class ASA 0.3B0.1, 0.3B0.2, 0.6B0.5*

Rated Voltage 15 KV

Wire 2

Phase 1

Frequency 25/60 cycles

Style Dry-type Indoor

Accuracy marked on nameplate.

Description: The manufacturer has asked, and his request has been granted, that Approval Circular SD-EA.207 of September 1, 1955 be amended in two instances, as follows: (1) the 600 amp. and 800 amp. ratings be deleted from the approved primary current ratings, and (2) the "Accuracy Class" be changed to ASA 0.3BO.1, 0.3B0.2, 0.6B0.5

The same description as outlined in Approval Circular SD-EA.207 applies.

Note: The same note as on Approval Circular SD-RA, 207 applies. This circular should be attached to SD-EA.207.

E. F. Cower

E. F. Power. Assistant Director, (E&G), Standards Division.

R. W. MacLean. Director. Standards Division.

