

TRADE AND COMMERCE
CANADA

SD-EA.214

STANDARDS DIVISION

OTTAWA, October 13, 1955.

TYPE APPROVALSANGAMO TYPE "LP" VOLTAGE TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "LP" Voltage Transformer, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus:

Rated Voltage 275-110 or 285-114, and 345-115
Frequency 60 cycles
Maximum Service Voltage 600

Description: These transformers are identical in all respects to the transformers approved in Circular SD-EA.1 of August 5, 1947, and this approval merely extends the previous approval to include the above additional ratings.

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLeay,
Director,
Standards Division.

