



STANDARDS DIVISION

OTTAWA, November 2, 1955.

TYPE APPROVALCANADIAN WESTINGHOUSE TYPE "SM-5" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "SM-5" Current Transformer, manufactured by the Canadian Westinghouse Company, Limited, Hamilton, Ontario.

Rating of Apparatus:

Primary Current 100 amperes
 Secondary Current 5 amperes
 Rated Voltage 5 KV
 Accuracy Class ASA 0.3B0.1, 0.3B0.5, 0.3B2.0*
 Wire 2
 Phase 1
 Frequency 25/60 cycles
 Style Dry Indoor

* shown on nameplate.

Description: This transformer, except for the primary current rating, is similar in all respects to the 25-5 ampere type "SM-5" approved on Circular SD-EA.217 of October 13, 1955.

R. W. MacLean
 R. W. MacLean,
 Director,
 Standards Division.

E. F. Power

E. F. Power,
 Assistant Director (E&G),
 Standards Division.

Ref: A-435A

