

TRADE AND COMMERCE  
CANADA

## STANDARDS DIVISION

OTTAWA,.....November 21, 1955.

MODIFICATIONS OF TYPE APPROVALCANADIAN WESTINGHOUSE TYPES "CA" AND "CS"  
POLYPHASE WATTHOUR METERS

The modifications to the apparatus specified and illustrated herein have been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Types "CA-2", "CA-3", "CA-5", "CA-8", "CS-2", "CS-3", "CS-5", "CS-7", "CS-8" and "CB-2" Polyphase Watthour Meters, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

Rating of Apparatus: All previously-approved ratings and capacities.

Modifications: The modifications approved herewith consist of the use of alnico permanent magnets on all the above types of meters and, as a result of the use of the newer magnets, a new design of nameplate; otherwise there has been no change in the meters.


*E. F. Power*

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

*R. W. MacLean*

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-504



CANADIAN WESTINGHOUSE TYPE "CS-5" WATTHOUR METER

