



TRADE AND COMMERCE  
CANADA

## STANDARDS DIVISION

OTTAWA, January 23, 1956.

TYPE APPROVALPACKARD TYPE "LM" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "LM" Current Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

## Rating of Apparatus:

Primary Current ..... 10, 15, 20 amperes  
 Secondary Current ..... 5 amperes  
 Accuracy Rating ..... ASA 0.6B0.2  
 Rated Voltage ..... 600 volts  
 Wire ..... 2  
 Frequency ..... 60 cycles  
 Style ..... Dry Indoor.

Description: These transformers are to the same design as those approved under Circulars SD-EA.127 of October 26, 1953 and SD-EA.138 of January 5, 1954; the range is thus extended to include the 10/5, 15/5, 20/5 ratios.

*E. F. Power*

E. F. Power,  
 Assistant Director (E&G),  
 Standards Division.

*R. W. MacLean*  
 R. W. MacLean,  
 Director,  
 Standards Division.

Ref: A-331

