

TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, April 13, 1956.

MODIFICATIONS OF TYPE APPROVALCANADIAN WESTINGHOUSE TYPES "CA" AND "CS-1"
SINGLE-PHASE WATTHOUR METERS

The modifications to the apparatus specified herein have been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Types "CA" and "CS-1" Single-Phase Watthour Meters, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

Rating of Apparatus: All previously-approved ratings and capacities.

Modifications: The modifications approved herewith consist of the use of Alnico permanent magnets on the above types of meters and, as a result of the use of the newer magnets, a new design of nameplate. In all other respects the meters are as previously approved.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-549

