



TRADE AND COMMERCE  
CANADA

SD-EA. 255

## STANDARDS DIVISION

OTTAWA, July 24, 1956.

TYPE APPROVAL

HYDRO-ELECTRIC POWER COMMISSION  
TYPE "H-15" VOLTAGE TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "H-15" Voltage Transformer, manufactured or modified expressly to specifications of the Hydro-Electric Power Commission of Ontario, 620 University Avenue, Toronto 2, Ontario, by Supreme Power Supplies, Mimico, Ontario.

## Rating of Apparatus:

Primary Voltage Rating ..... 7200  
 Secondary Voltage Rating ..... 120  
 Insulation Class ..... 15 KV  
 Accuracy Rating ..... ASA 0.3Y 0.6Z  
 Frequency ..... 60 cycles.

Description: These voltage transformers are 3 Kva distribution transformers, manufactured or modified to Ontario Hydro specifications by Supreme Power Supplies, Mimico, Ontario. They are essentially similar to those approved under Approval Circular SD-EA.153, June 15, 1954.

Note: Those Inspection Districts situated outside the Province of Ontario need not be concerned with this approval notice.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-574

