



TRADE AND COMMERCE
CANADA

SD-EA.256

STANDARDS DIVISION

OTTAWA, July 31, 1956.

TYPE APPROVALPACKARD TYPE "E2.5" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "E2.5" Current Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current	60 amperes
Secondary Current	5 amperes
Voltage Rating	2.5 KV
Accuracy Rating - at 60 cycles ...	0.3B0.1, 0.3B0.5*, 0.3B0.9, 0.6B2.0
- at 25 cycles ...	0.6B0.1, 0.6B0.5, 0.6B0.9, 0.6B2.0
Frequency	25-60 cycles
Style	Dry Indoor

* shown on nameplate.

Description: These transformers are identical in design to the type "E2.5" in various ratings previously approved under Circulars SD-EA.195, SD-EA.203, SD-EA.220 and SD-EA.229. The 60-ampere rating approved herein is, therefore, to be included in the ratings listed in Circular SD-EA.229.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-458

