

TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, September 12, 1956.

MODIFICATION OF TYPE APPROVALSANGAMO TYPE "S-3S"
HORIZONTAL POLYPHASE WATTHOUR METER

The modification to the apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Type "S-3S" Horizontal Polyphase Watthour Meter, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus: 50-ampere rating only, as previously approved.

Modification: The modification consists of a change in the maximum ampere rating only of the 50-ampere type "S-3S" polyphase meter. This particular meter, previously approved with a maximum current rating of 100 amperes, has now, in addition, been approved for a maximum current rating of 150 amperes when used with a high capacity type socket. As before, the nameplate will be stamped "50 amperes nominal, 100 amperes maximum". The additional marking "150 amp. max. with H.C. Socket" will appear on the face of the register to the left of, and above the space provided for the customer's number.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-423

