

TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, November 13, 1956.

TYPE APPROVALCANADIAN WESTINGHOUSE TYPE "SM-5" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "SM-5" Current Transformer, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

Rating of Apparatus:

Primary Current	10, 15, 20, 25, 30, 40, 50, 75, 100, 150 200, 300, 400, 600 and 800 amperes
Secondary Current	5 amperes
Rated Voltage	5 KV
Accuracy Class	ASA 0.3B0.1, 0.3B0.5, 0.3B2.0*
Wire	2
Frequency	25 - 60 cycles
Style	Dry Indoor

* shown on nameplate.

Description: These transformers, except for the primary current rating, are similar in all respects to the 25-5 ampere type "SM-5" approved and described in Approval Circular SD-EA.217 of October 13, 1955. The 100-5 ampere ratio has also been approved previously in Approval Circular SD-EA. 219 of November 2, 1955. Both the 25-5 and 100-5 ratings have been included in this circular to make the listing complete herein.

E. F. Power,
Assistant Director (E.C.),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-435B

