

TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, March 28, 1957.

TYPE APPROVALHYDRO-ELECTRIC POWER COMMISSION
TYPE "H-15" VOLTAGE TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "H-15" Voltage Transformer, manufactured or modified expressly to specifications of The Hydro-Electric Power Commission of Ontario, 620 University Avenue, Toronto 2, Ontario, by Canadian Westinghouse Company Limited, Hamilton, Ontario.

Rating of Apparatus:

Primary Voltage Rating 7200 volts
 Secondary Voltage Rating 120 volts
 Insulation Class 15 KV
 Accuracy Rating ASA 0.3Y, 0.6Z
 Frequency 60 cycles

Description: These voltage transformers are type SC 3-KVA distribution transformers, manufactured or modified to Ontario Hydro specifications by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

Polarity is indicated by H₁ and X₁ painted prominently on the tank adjacent to the appropriate terminals.

E. F. Power,
 Assistant Director (E&G),
 Standards Division.

R. W. MacLean,
 Director,
 Standards Division.

Ref: A-637

1

2