



## STANDARDS DIVISION

OTTAWA, April 30, 1957.

MODIFICATION OF TYPE APPROVALSANGAMO TYPE "CJS" SINGLE-PHASE WATTHOUR METER

The modification to the apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Type "CJS" Single-Phase Watthour Meters, manufactured by the Sangamo Company Limited, Leaside. Toronto 17, Ontario.

Rating of Apparatus: As previously approved. See Circular SD-EA.258 of August 10, 1956.

Modification: On the type "CJS" meter approved under Circular SD-EA.258 there are two potential disconnects on the back of the meter. As originally approved the sliding part of each disconnect was connected to the potential coil of the meter by means of a stud which passed through the plastic back and was attached to the potential lead by means of a screw. The modification consists in making this connection by means of a spring clip. The clip, which is affixed to the potential lead, engages with a small knob on the stud which passes through the meter.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-639

