



TRADE AND COMMERCE
CANADA

SD-EA.293

STANDARDS DIVISION

OTTAWA, May 1, 1957.

TYPE APPROVALPACKARD TYPES "E-5" AND "E-15" CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "E-5" and "E-15" Current Transformers, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current 25/50 and 200/400 amperes

Secondary Current 5 amperes

Voltage Rating 5 KV and 15 KV

Accuracy Rating:

	<u>60 cycles</u>			<u>25 cycles</u>		
Lower Ratio	0.3B0.1,	0.3B0.5 [*] ,	0.6B2.0	0.6B0.1,	0.6B0.5,	0.6B2.0
Higher Ratio	0.3B0.1,	0.3B0.5 [*] ,	0.3B2.0	0.3B0.1,	0.3B0.5,	0.3B2.0

Frequency 25-60 cycles

Style Dry Indoor

* shown on nameplate.

Description: These transformers are the same as those approved under Circular SD-EA.247, June 4, 1956.

E. F. Power
(for) E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean
R. W. MacLean,
Director,
Standards Division.

Ref: A-596

