

TRADE AND COMMERCE
CANADA

SD-EA.313

STANDARDS DIVISION

OTTAWA, September 20, 1957.

TYPE APPROVALPACKARD TYPE "P5" DOUBLE-RATIO CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "P5" Double-Ratio Current Transformers, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current 1000/2000 amperes
Secondary Current 5 amperes
Accuracy Rating 0.3B0.1, B0.5, 0.6B2.0 for 1000-5 amperes, and
0.3B0.1, B0.5, B2.0 for 2000-5 amperes.
Rated Voltage 5 KV
Wire 2
Frequency 60 cycles
Style Dry Indoor.

Description: These transformers are identical to the type "P5" approved on July 18, 1957 under Circular SD-EA.304 except that secondary winding is in two parts and brought out to three terminals to give the double range.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-606A

