



TRADE AND COMMERCE
CANADA

SD-EA.316

STANDARDS DIVISION

OTTAWA, September 25, 1957.

TYPE APPROVALPACKARD TYPES "P-" AND "R-" CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "P5", "P8.7", "P15", "R5", "R8.7" Current Transformers, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current 1000 amperes
 Secondary Current 5 amperes
 Accuracy Rating ASA 0.3B0.1, 0.3B0.5^{*}, 0.3B0.9, 0.3B2.0
 Rated Voltage 5 KV, 8.7 KV, 15 KV (type "P" only)
 Wire 2
 Frequency 60 cycles
 Style Dry Indoor

^{*}shown on nameplate.

Description: These transformers are the same as those approved under SD-EA.304, July 18, 1957 except that the core area has been slightly increased to ensure that the stated accuracy will be met.

Please note that type "R15" is not included in this approval.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-606B

