

Mik. Coyne



TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, December 30, 1957.

TYPE APPROVAL

PACKARD TYPE "H-H15" VOLTAGE TRANSFORMER

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "H-H15" Voltage Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Voltage	13,800
Secondary Voltage	115/115
Accuracy Rating	0.3WXYZ/0.3WXYZ
Insulation Class	15 KV
Frequency	60 cycles
Style	Outdoor Service, Oil-Filled with Top H.V. and L.V. Bushings

Description: The coil and core design of these transformers is the Distribution Transformer type using lock wound core. The assembly is made with cover mounted bushings. The tank is provided with hanger lugs for pole mounting. A diagram nameplate is provided showing the connections as well as the ratings.


E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. Maclean

R. W. Maclean,
Director,
Standards Division.

Ref: A-710



PACKARD TYPE "H-H15" VOLTAGE TRANSFORMER

