



TRADE AND COMMERCE  
CANADA

SD-EA.337

## STANDARDS DIVISION

OTTAWA, February 3, 1958.

MODIFICATION OF TYPE APPROVALSANGAMO TYPE "LP" VOLTAGE TRANSFORMERS

The modification to the apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Type "LP" Voltage Transformers, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.

## Rating of Apparatus:

Voltage Rating .....	575 to 115
	460 to 115
	345 to 115
	275 to 110 or 285 to 114
	230 to 115
	115 to 115
Accuracy Class .....	1.2W
Frequency .....	60 cycles
Insulation Class .....	0.6KV

Modification: Type "LP" voltage transformers have been approved under Approval Circulars SD-EA.1, August 5, 1947; SD-EA.214, October 13, 1955; and SD-EA.269, November 9, 1956. Under this modification single units will continue to be marked type "LP", but dual and triple assemblies for use in metering units will be designated and marked types "LP2" and "LP3".

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-601A

