



TRADE AND COMMERCE  
CANADA

SD-EA.340

## STANDARDS DIVISION

OTTAWA, February 24, 1958.

TYPE APPROVAL

Ferranti Type "FTA" Single-Phase Combination  
Thermal Demand Watthour Meter

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R. S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "FTA" Single-Phase Combination Thermal Demand Watthour Meter, manufactured by the Ferranti Electric Limited, Toronto, Ontario.

## Rating of Apparatus:

Nominal Amperes .....	25
Maximum Amperes .....	75
Volts .....	115 or 120
Wire .....	2
Test Period (in minutes) ....	32
Phase .....	1
Frequency .....	50- and 60-cycles

## Description

The meter approved herein is identical in all respects to the Type "FTA" approved under Circulars SD-EA.206, SD-EA.208, SD-EA.274, and SD-EA.283.

*R. W. MacLean*  
R. W. MacLean,  
Director,  
Standards Division.

A-731

*E. F. Power*

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

