



TRADE AND COMMERCE
CANADA

SD.EA. 341

STANDARDS DIVISION

OTTAWA.....February 25, 1958.....

TYPE APPROVAL

Packard Type "CC" Voltage Transformer

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R. S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "CC" Voltage Transformer, manufactured by the Packard Electric Company, Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Voltage	7700/13,337Y volts
Secondary Voltage	110 volts
Accuracy Classification	0.3WXY, 0.6Z
Frequency	60 cycles

Description: This transformer is designed for use in metering units in conjunction with current transformers. The primary and secondary leads are identified by fibre tags marked H₁ and H₂, and X₁ and X₂ respectively.

E. F. Power,
Assistant Director (E&C),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-685

