

TRADE AND COMMERCE
CANADA

SD-EA, 352c

STANDARDS DIVISION

OTTAWA, December 16, 1958.

TYPE APPROVALCANADIAN WESTINGHOUSE TYPES "DAH" AND "DSH"
COMBINATION THERMAL DEMAND-ENERGY METERS

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "DAH" and "DSH" Combination Thermal Demand-Energy Meters, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

Rating of Apparatus: See Circulars SD-EA.352a and SD-EA.352b of April 24, 1958 and July 10, 1958 respectively.


Description: The approval granted herein authorizes the use of a direct-reading demand scale, 0-24 kilowatts, with a multiplier of 1 (for both readings) on the above types of demand-energy meters, as well as the previously-approved 0-1200 watts demand scale using a multiplier of 20 (for both readings).

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean
R. W. MacLean,
Director,
Standards Division.

Ref: A-745



CANADIAN WESTINGHOUSE TYPE "DSH" DEMAND-ENERGY METER

