SD-EA.357



## STANDARDS DIVISION

May 29, 1958. OTTAWA....

## TYPE APPROVAL

## PACKARD TYPES "KC25", "E8.7" AND "E8.7 SPECIAL" CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "KC25", "E8.7" and "E8.7 Special" Current Transformers. manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Lower Ratios, 60 cycles	5 amperes 25 KV (in tank and oil-insulated) 8.7 KV (dry) 15 KV (in oil) 0.3B0.1, B0.5, B0.9, B2x0.9, B2.0 0.3B0.1, B0.5, B0.9, B2x0.9, B2.0
Frequency	25 and 60 cycles Oil-Insulated Dry Indoor

\* shown on nameplate.

Description: The transformers approved herein are identical to those previously approved under Circular SD-EA.334 of January 15, 1958. The 5/10 ampere rating is to be included with the ratings previously approved.

Director, Standards Division. E. F. Power. Assistant Director (E&G), Standards Division.

8.7. Cower

Ref: A-708

