

TRADE AND COMMERCE
CANADA

SD-EA.367

STANDARDS DIVISION

OTTAWA, August 5, 1958.

TYPE APPROVALPACKARD TYPE "CFX" VOLTAGE TRANSFORMER

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "CFX" Voltage Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Voltage 13,800 volts
Secondary Voltage 115 volts
Frequency 60 cycles
Accuracy Rating 0.3W,X,Y,Z (shown on nameplate).


Description: This transformer is a conventional lock wound core design impregnated with compound and mounted in a compound-filled metal case. It is designed for use with fuses which are mounted on four bushings, two of which are dummies on one side.

E. F. Pover

E. F. Pover,
Assistant Director (E&G),
Standards Division.

R. W. MacLean
R. W. MacLean,
Director,
Standards Division.

Ref: A-773



PACKARD TYPE "CFX" VOLTAGE TRANSFORMER

