



TRADE AND COMMERCE
CANADA

SD-EA.373

STANDARDS DIVISION

OTTAWA, September 17, 1958.

TYPE APPROVALFERRANTI-PACKARD TYPE "LM" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "LM" Current Transformer, manufactured by the Ferranti-Packard Electric Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current 5 amperes
 Secondary Current 5 amperes
 Accuracy Rating 0.6B0.2
 Rated Voltage 600 volts
 Wire 2
 Frequency 60 cycles
 Style Dry Indoor.

Description: This transformer is identical in design to the Packard Type "LM" approved under Circular SD-EA.223 of January 23, 1956. The range for the type "LM" transformer is thus further extended to include the 5-5 ampere rating.

E. F. Power,
 Assistant Director (ESG),
 Standards Division.

R. W. MacLean,
 Director,
 Standards Division.

Ref: A-331 H

