



TRADE AND COMMERCE
CANADA

STANDARDS BRANCH

SD-EA, 376 - AMENDED
Cancelling and Replacing
SD-EA.376 of Oct.29,1958

OTTAWA, May 26, 1960.

TYPE APPROVAL

FERRANTI-PACKARD TYPE "MS15" VOLTAGE TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "MS15" Voltage Transformer, manufactured by Ferranti-Packard Electric Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Voltage	7200/12470Y
Secondary Voltage	120
Accuracy Rating	0.3W,X,Y,Z,ZZ
Insulation Class	15 KV
Frequency	60 cycles
Style	Outdoor Oil-Filled.

Description: These transformers are identical in design to the type "FH-15" voltage transformers approved on SD-EA.302 of July 9, 1957, except that the low voltage bushings are replaced by a conduit box.

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Branch.

R. W. MacLean

R. W. MacLean,
Director,
Standards Branch.

Ref: A-663

