

TRADE AND COMMERCE  
CANADA

SD-EA. 398

## STANDARDS DIVISION

OTTAWA April 13, 1959.

TYPE APPROVALFERRANTI-PACKARD TYPES "FUI5" AND "RUI5"  
OUTDOOR COMPOUND-FILLED CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "FUI5" and "RUI5" Outdoor Compound-Filled Current Transformers, manufactured by Ferranti-Packard Electric Limited, St. Catharines, Ontario.

## Rating of Apparatus:

Primary Current .....	2500 amperes
Secondary Current .....	5 amperes
Voltage Rating .....	15KV
Accuracy Rating:	
60 cycles .....	0.3B0.1, B0.5 <sup>*</sup> , B0.2, B2.0
25 cycles .....	0.3B0.1, B0.5 <sup>*</sup> , B0.2, 0.6B2.0
Frequency .....	25/60 cycles
Style .....	Outdoor Bushing or Ring Type Compound-Filled

\* stamped on nameplate.

Description: The transformers approved herein are identical to the transformers previously approved under Circular SD-EA.338 of February 6, 1958.

E. F. Power,  
Assistant Director (Eng),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-732

