

TRADE AND COMMERCE
CANADA

SD-EA.308

STANDARDS DIVISION

OTTAWA..... August 19, 1957.....

TYPE APPROVALCANADIAN WESTINGHOUSE TYPE "D" CLOCK-TYPE REGISTERS
FOR TYPES "DA" AND "DS" WATTHOUR METERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "D" Clock-Type Registers for use with types "DA" and "DS" watthour meters, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

Rating of Apparatus: These registers may be used with any approved rating of types "DA" and "DS" watthour meters.

Description: These clock-type registers which supersede the formerly-used register feature a finger-operated gear de-mesh which permits fast register reset.

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean
R. W. MacLean,
Director,
Standards Division.

Ref: A-659

