



S-EA.414

TRADE AND COMMERCE
CANADA

STANDARDS BRANCH

OTTAWA.....October 7, 1959.

MODIFICATION OF TYPE APPROVAL

SANGAMO TYPES "DEA" and "DES" THERMAL
DEMAND-ENERGY METERS

The modification to the apparatus specified herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Types "DEA" and "DES" Combination Thermal Demand-Energy Meters, manufactured by Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus: All ratings approved under SD-EA.395 of March 16, 1959, SD-EA.403 of May 6, 1959, and SD-EA.409 of July 21, 1959.

Modification: This approval permits the use of ball type lower bearings in any of the ratings included in the circulars listed above.

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Branch.

R. W. MacLean

R. W. MacLean,
Director,
Standards Branch.

Ref: A-778

1

2

3