

TRADE AND COMMERCE
CANADA

S-EA.443

STANDARDS BRANCH

OTTAWA..... March 23, 1960.

MODIFICATION OF TYPE APPROVALCANADIAN WESTINGHOUSE TYPES "DA" AND "DAH" BASE ASSEMBLY

The modifications to the apparatus specified herein have been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Types "DA" and "DAH" Base Assembly, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

Rating of Apparatus: For use in any approved ratings of Types "DA" and "DAH" meters.

Modifications: The base assembly is common to both the thermal combination (type "DAH") and single-phase watt-hour (type "DA") meters. The modified components differ from those now approved in the following ways:-

- (1) Terminal Block - The cable aperture has been increased in height to approximately 1/2" (formerly 7/16")
- (2) Potential Disconnects - The disconnects will be of the spring type, thus eliminating the screws.
- (3) Base - The base has been modified to provide a groove in which a neoprene cover gasket will be mounted and held captive.
- (4) Cover - The cover is similar to existing covers except the gasket has been removed.

E. F. Power,
Assistant Director (E&G),
Standards Branch.

R. W. MacLean,
Director,
Standards Branch.

Ref: A-797G

