



TRADE AND COMMERCE
CANADA

STANDARDS BRANCH

OTTAWA, April 7, 1960.

TYPE APPROVAL

FERRANTI-PACKARD TYPES "B2TA" AND "B2TS"
SINGLE-PHASE COMBINATION THERMAL DEMAND-ENERGY METERS

The apparatus specified herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "B2TA" and "B2TS" Single-Phase Combination Thermal Demand-Energy Meters, manufactured by Ferranti-Packard Electric Limited, St. Catharines, Ontario.

Rating of Apparatus:

Current Range	5-50 amperes
Voltage	230 or 240 volts
Wire	3
Test Period	32 minutes
Scale Graduation	1200
Full Scale Value	12 KW
*Multiplier	10
Register Type	Clock and Cyclometer
Phase	1
Frequency	60 cycles

*Multiplier applies to both watthour and demand readings.

Description: Except for the current rating, these meters are the same as the types "B2TA" and "B2TS" described in Circulars S-EA.432, January 4, 1960, S-EA.437, January 18, 1960 and S-EA.438, March 9, 1960.

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Branch.

R. W. MacLeary

R. W. MacLeary
Director,
Standards Branch.

Ref: A-851B

