



TRADE AND COMMERCE  
CANADA

STANDARDS BRANCH

OTTAWA September 16, 1960.

TYPE APPROVAL

FERRANTI-PACKARD TYPE "MC15" VOLTAGE TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "MC15" Voltage Transformer, manufactured by Ferranti-Packard Electric Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Voltage .....	14,400 volts
Secondary Voltage .....	120 volts
Frequency .....	60 cycles
Accuracy Rating .....	0.3W, X, Y, Z <sup>†</sup> , ZZ

\* shown on nameplate.

Description: This transformer is similar to the type "CFX" approved under SD-EA.367 of August 5, 1958 except that it is immersed in oil when used in metering units.

*E. F. Power*

E. F. Power,  
Chief, Electricity & Gas Division,  
Standards Branch.

*R. W. MacLean*

R. W. MacLean  
Director,  
Standards Branch.

Ref: A-773

