

TRADE AND COMMERCE
CANADA

S-EA.494

STANDARDS BRANCH

OTTAWA January 24, 1961.

TYPE APPROVALSANGAMO FIVE-DIAL CLOCK REGISTER

The apparatus specified and illustrated herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Five-Dial Clock Register for use on type "NB" watthour meters, manufactured by Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Description of Apparatus: The construction is similar to the regular four-circle register, but with smaller diameter circles. The fifth circle is added at the end of the train. A test dial is provided in the usual location. This register avoids the necessity for a multiplier of 10.

E. F. Power

E. F. Power,
Chief, Electricity & Gas Division,
Standards Branch.

R. W. MacLean
R. W. MacLean,
Director,
Standards Branch.

Ref: A-769E

2

2

1

1

1

SANGAMO FIVE-DIAL CLOCK REGISTER



