



TRADE AND COMMERCE  
CANADA

STANDARDS BRANCH

OTTAWA May 4, 1961.

TYPE APPROVAL

CANADIAN WESTINGHOUSE TYPE "PT .6" VOLTAGE TRANSFORMER

The apparatus specified and illustrated herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "PT .6" Voltage Transformers, manufactured by the Canadian Westinghouse Company Limited, London, Ontario.

Rating of Apparatus:

Primary Voltage ..... 120, 240, 300, 360, 480 or 600 volts  
 Secondary Voltage ..... 120 volts  
 Accuracy Rating ..... 0.6W, 1.2X  
 Frequency ..... 60 cycles  
 Insulation Class ..... 600 volts  
 Style ..... Indoor  
 Rating ..... 200VA thermal, 4KV 60 cycles 1 min.  
 and 10KV F.W. impulse.

Description: These transformers are of epoxy moulded construction, the terminals being brass studs mounted on the top with the HV and LV studs on opposite sides of the transformer. HV letters are moulded between the HV terminals for identification and the polarity marks are raised moulded dots painted with white oil paint.

*J.R. Gardiner*

(for) E. F. Power,  
 Chief, Electricity & Gas Division,  
 Standards Branch.

*R. W. MacLean*  
 R. W. MacLean,  
 Director,  
 Standards Branch.

Ref: A-905



CANADIAN WESTINGHOUSE TYPE "PT .6" VOLTAGE TRANSFORMER



