



TRADE AND COMMERCE
CANADA

STANDARDS BRANCH

OTTAWA June 20, 1961.

TYPE APPROVALCANADIAN WESTINGHOUSE TYPE "MCT-5" CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R. S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "MCT-5" Current Transformers, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

Rating of Apparatus:

Primary Current 500 amperes
 Secondary Current 5 amperes
 Voltage Rating 5 KV
 Accuracy Rating 0.3B0.1, B0.2, B0.5, B0.9*, B(2x0.9), B1.0; 0.6B2.0
 Wire 2
 Frequency 60 cycles
 R.F. (rating factor) 1.5
 Style Dry Indoor

* marked on nameplate.

Description: This is an additional ratio to the transformers which received approval under Circular S-EA.460-AMENDED, February 22, 1961. This transformer, except for the ratio, is identical electrically and mechanically to those ratios listed in the above-mentioned circular.

E. F. Power,
Chief, Electricity & Gas Division,
Standards Branch.

R. W. MacLean,
Director,
Standards Branch.

Ref: A-8700

