

TRADE AND COMMERCE
CANADA

S-EA.511

STANDARDS BRANCH

OTTAWA, June 23, 1961.

TYPE APPROVALCANADIAN WESTINGHOUSE 5-DIAL REGISTER WITH MULTIPLIER OF "1"
FOR USE WITH TYPE "MS-5" POLYPHASE WATTHOUR METER

The apparatus specified herein has been duly approved by the Standards Branch under the provisions of the *Electricity Inspection Act*, Chapter 94, R. S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: 5-Dial Register with multiplier of "1" for use with "MS-5" polyphase watthour meter, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

Description: The register approved herein is essentially the same as that approved under SD-EA.23, May 23, 1950 for the type "CS-1" watthour meter. This register may be used only with the type "MS-5" polyphase watthour meter approved under S-EA.450, May 25, 1960, and is limited to the 1.2-100 ampere, 120- or 240-volt (115 or 230) rating only.

E. F. Power

E. F. Power,
Chief, Electricity & Gas Division,
Standards Branch.

R. W. MacLean
R. W. MacLean,
Director,
Standards Branch.

Ref: A-825B

