

TRADE AND COMMERCE
CANADA

STANDARDS BRANCH

S-EA.518

OTTAWA August 23, 1961.

TYPE APPROVALCANADIAN WESTINGHOUSE TYPE "KT-.6" CURRENT TRANSFORMERS

The apparatus specified and illustrated herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "KT-.6" Current Transformers, manufactured by the Canadian Westinghouse Company Limited, London, Ontario.

Rating of Apparatus:

Primary Current	1000 and 1200 amperes
Secondary Current	5 amperes
Voltage Rating6 KV
Accuracy Rating: (60 cycles)	0.3B0.1, B0.2, B0.5, B0.9 [*] ; 0.6B(2x0.9) [*]
(25 cycles)	0.3B0.1, B0.2, B0.5, B0.9
Wire	2
Frequency	25 or 60 cycles
Style	Dry Indoor
Rating Factor (R.F.)	1.33 for 1000-5 rating
	1.0 for 1200-5 rating

* marked on nameplate.

Description: This is an extension of the approval granted under S-EA.496, February 15, 1961, to include the 1000-5 and 1200-5 ratios. Except for the ratios, the accuracy ratings and the rating factors, these transformers are identical with those previously approved.

E. F. Power

E. F. Power,
Chief, Electricity & Gas Division,
Standards Branch.

R. W. MacLean
R. W. MacLean,
Director,
Standards Branch.

Ref: A-900C

CANADIAN WESTINGHOUSE TYPE "KT-.6" CURRENT TRANSFORMER



