



TRADE AND COMMERCE  
CANADA

STANDARDS BRANCH

OTTAWA January 11, 1962.

TYPE APPROVAL

CANADIAN WESTINGHOUSE TYPE "FT 1.2A"  
VOLTAGE TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "FT 1.2A" Voltage Transformers, manufactured by the Canadian Westinghouse Company Limited, London, Ontario.

Rating of Apparatus:

- Primary Voltage ..... 240, 480 and 600 volts
- Secondary Voltage ..... 120 volts
- Accuracy Rating ..... 0.3%<sup>X</sup>, 1.2%<sup>Y</sup>\*
- Frequency ..... 60 cycles
- Insulation Class ..... 1.2 kV
- Style ..... Indoor
- Rating ..... 750 VA thermal, 10 KV 60 cycles 1 min.  
and 30 KV P.M. impulse

\*"0.3%<sup>X</sup>, 1.2%<sup>Y</sup>" marked on nameplate.

Description: The type "FT 1.2A" is identical electrically and physically with the type "FT 1.2" receiving approval under circular S-EA.503, May 4, 1961, except (1) there is no 120-120 volt ratio in the line, (2) the accuracy rating is different, and (3) the thermal rating has been indicated to be 750 VA.

*E. F. Power*  
E. F. Power,  
Chief, Electricity & Gas Division,  
Standards Branch.

*R. H. MacLean*  
R. H. MacLean,  
Director,  
Standards Branch.

Ref: A-240

