

SEICE OF THE DIRECTOR

PLEASE QUOTE FILE

## TRADE AND COMMERCE CANADA

## STANDARDS BRANCH

February 15, 1963. OTTAWA

## TYPE APPROVAL

## CANADIAN WESTINGHOUSE TYPE "KT15" CURRENT TRANSFORMERS

The apparatus specified and illustrated herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "KT15" Current Transformers, manufactured by the Canadian Westinghouse Company Limited, London, Ontario.

Rating of Apparatus:

Primary Currents ..... 5, 10, 15, 20, 25, 30, 40, 50, 75, 100, 150, 200, 300, 400, 500, 600, 800, 1000, 1200 amperes

Secondary Current ..... 5 amperes

Voltage Rating ...... 15KV

Acouracy Rating:

1000-5 ratio only ... 0.380.1, B0.2, B0.5, B0.9, B( $2\pi0.9$ )\*, B1.0; 0.6B2.0\* All other ratios ... 0.3B0.1, B0.2, B0.5, B0.9, B( $2\pi0.9$ ), B1.0, B2.0\*

Wire ..... 2

Frequency ..... 60 cycles

R.F. (rating factor):

1200-5 ratio ...... 1.0 1000-5 ratio ...... 1.33 All other ratios .... 1.5

Style ..... Dry Indoor

Insulation Rating ..... 34KV 1 minute, 110KV F.W. Impulse

\* marked on nameplate.

Description: The type "KT15" current transformers are of moulded construction having the primary winding brought out to bars extending from each end of the transformer. The secondary terminals are located in a recess moulded into the top of the transformer. The polarity is subtractive and white dots are moulded adjacent to the identified primary and secondary terminals, the latter being protected by a transparent plastic cover with an off-centre hole in each of the two flat unequal sides. A finger-operated short-circuiting device has attached to it a fibre stamping having two projections that fit into one or the other of the holes in the plastic cover. When the secondary is open-circuited, the plastic cover can only be installed in a way that places the short side to the front, thus uncovering the entrance to the terminals for the leads.

(for) E. F. Power,

Chief, Electricity and Gas Division,


Standards Branch.


R. W. MacLean, Director,


Standards Branch.

Ref: A-982











CANADIAN WESTINGHOUSE TYPE "KT15" CURRENT TRANSFORMER





4,545,557 \_\_\_