



S-EA.493  
(amended)

DEPARTMENT OF TRADE AND COMMERCE  
STANDARDS BRANCH

OTTAWA April 8, 1964.

MODIFICATION OF TYPE APPROVAL

SANGAMO TYPE 4L2 2-ELEMENT AND 2 1/2 ELEMENT Y  
COMBINATION POLYPHASE DEMAND ENERGY METER

The modifications to the apparatus specified herein have been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Modified: Type 4L2 2 Element and 2 1/2 Element Y Combination Polyphase Demand-Energy Meters, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus:

3 Phase 3 wire (2-Element)

Voltages	115	120	230	240	460	480	575	600 volts
Ampere Rating	.12-7.5*	.12-5**	.25-15*	.25-10**	.5-37.5	1.2-75	2.5-150	
° Full Scale Kilowatts	1.5	1	3	2	7.5	15	30	
Multiplier	1	1	2	2	5	10	20	
° Disc Const. (Kh each disc)	1/6	1/6	1/3	1/3	1	1-2/3	3-1/3	
Register Ratio (Rr) overall	6000	6000	6000	6000	5000	6000	6000	
Maximum amperes at rated kW and volts	7.5	5	15	10	37.5	75	150	
Response period	10 and 16 minutes - all ratings							
Frequency	50 and 60 cycles - all ratings							
Register	Clock type, individual on each element, or differential for totalizing readings of both elements (S-EA.493).							

.....2



3 Phase 4 wire (2 1/2 Element Y)

Voltages	120 volts			
Current Ranges, amperes	0.12-6.0**	0.12-8.5*	0.5-40	1.2-85
Full Scale, Kilowatts	2	3	15	30
# Multiplier	2	2	10	20
Disc Constant (Kh) each disc	1/2	1/2	2 1/2	5
Register Ratio (Rr) overall	4000	4000	4000	4000
Maximum Amperes at rated KW and volts	5.66	8.33	41.67	83.3
Response Period	10 and 16 minutes - all ratings			
Frequency	50 and 60 cycles - all ratings			
Register	Block type, individual on each element, or differential for totalizing readings of both elements (S-EA.493).			

- \* May be transformer type or self-contained 1500 watt scale.
- \*\* Transformer type with 1000 watt scale
- o Full Scale kilowatts, multiplier and disc constant are given for 115 or 120 volts.
- # Applies to both withhour and demand readings.

Modifications: The modifications to the existing type 4L2 involve:

(1) the use of the enclosed demand frame with dial and scale similar to that used in the 4L3 and

(a) all ratings are now current range rated, and the 2 1/2 element Y ratings of 0.75-50 and 1.5-100 amperes (receiving approval under SD-EA.266) have been changed to 0.5-40 and 1.2-85 respectively. The current ranges of the type 4L2 are now consistent with those of the types 4L3 and ED30.

This amendment covers the addition of the 1000 watt scale, which may be supplied in addition to the 1500 watt scale, in the transformer type of meter. Self-contained ratings will have 1500 watt scales. No other change is involved and the power factor selector switch will be found in the same place at the top of the cover.

This circular replaces S-EA.583 (amended) of March 6, 1964.

*wjg & mar*

(for) E. F. Power,  
Chief, Electricity and Gas Division,  
Standards Branch.

*R. W. MacLean*

R. W. MacLean,  
Director,  
Standards Branch.

Ref: A588C.

