



## DEPARTMENT OF TRADE AND COMMERCE

STANDARDS BRANCH

OTTAWA, August 20, 1963.

## Type Approval

## Canadian Westinghouse Type "OPC-" Dual Ratio Current Transformers

The apparatus specified and illustrated herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94. R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "OPC-" Dual Ratio Current Transformers manufactured by the Canadian Westinghouse Company Limited, London, Ontario.

Rating of Apparatus: Primary Currents

Secondary Current
\*\*Rated Insulation Class
#Accuracy Rating

Wire
Frequency
R.F. (rating factor)
Style
F.W. Impulse level

10/20, 20/40, 25/50, 50/100, 75/150, 100/200, 150/300, 200/400, 300/600, 400/800, 600/1200, 800/1600, 1000/2000 and 1200/2400 amperes 5 amperes 25KV, 34.5KV, 46KV and 69KV 0.3B0.1, B0.2, B0.5, B0.9, B(2x0.9), B1.0, B2.0


60 cycles
1.33
Beehive, outdoor, oil-filled
OPC25 150KV, OPC34.5 200KV, OPC46 250KV,
OPC69 350KV


\*Rated Insulation Class forms part of Type Designation, e.g. OPC34.5 # 0.3B0.1. 0.3B0.5, 0.3B2.0, 0.3B0.9, 0.3 (twice B0.9) marked on nameplate

Description: These transformers are made up of a beehive-shaped oil-filled porcelain shell with a metal base and top cover plate. The primary windings are terminated at four copper study etamped H<sub>1</sub>, H<sub>2</sub>, H<sub>3</sub>, H<sub>4</sub>, with a 90° spacing at the top of the porcelain shell just below the top cover.

Flexible leaf copper straps are provided for connecting the primary windings in series or in parallel to obtain the double ratio as indicated on the connection diagram on the nameplate.


The secondary winding is brought to two terminals marked  $X_1$  and  $X_2$  inside a watertight terminal box at the base of the transformer.






			e agger s

## Canadian Westinghouse Type "OPC-" Dual Ratio Current Transformers







-0.22

The nameplate is stamped 25-60 cycles, but this approval covers the use of these transformers for metering purposes on 60 cycles only.



E. F. Power

E. F. Power, Chinf, Electricity & Gas Division, Standards Branch.




Standarde Branch.
Ref: A746B

R. W. Maclean Director,







				1/102/7