

DEPARTMENT OF TRADE AND COMMERCE

STANDARDS BRANCH

November 28, 1963. OTTAWA.

TYPE APPROVAL

SANGAMO "MV-150" DUAL RATIO CURRENT TRANSFORMERS

The apparatus specified and illustrated herein have been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved:

Type "TW-150" Dual Ratio Current Transformers manufactured by Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus:

Primary Currents

10/5, 20/10, 30/15, 40/20, 50/25, 100/50, 150/75, 200/100, 300/150, 400/200, 600/300 amperes.

Secondary Current Voltage Rating Accuracy Rating High Ratio Low Ratio Frequency

Wire Pha ing factor) R.L

Sty1_ Thermal Rating, continuous

Thermal Rating, 1 second Short Time Mechanical Rating * marked on nameplate.

Description:

5 Amperes.

0.380.1, B0.2, B0.5, B0.9, B(2 x 0.9)

0.6B0.1, B0.2, B0.5, B0.9 60 cycles

1 1.5

15 KV.

Dry type, indoor. 1.5 x rated current. 110 x rated current.

250 x rated current.

These transformers are similar in design and appearance to the type MV-150 single ratio transformers receiving approval under S-EA.517 of August 21, 1961, except for a second set of secondary terminals at the opposite side at the top. The secondary winding is centretapped with leads running to the secondary terminals of the lower ratio. A single short-circuiting link is provided which will normally be found across the secondary terminals having the higher ratio.

R. W. MacLean

Director, Standards Branch.

Ref: A898A.


8.7. Power E. F. Power. Chief.

Electricity & Gas Division, Standards Branch.



















			Made
			Property





		10011
		Second Co.
		10000001