



DEPARTMENT OF TRADE AND COMMERCE
STANDARDS BRANCH

OTTAWA, August 17, 1964.

TYPE APPROVAL

CANADIAN GENERAL ELECTRIC TYPES "PV-1.2-", "PV-2.5-", "PV-5-",
"PV-8.7" and "PV-15-" VOLTAGE TRANSFORMERS

The apparatus specified and illustrated herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "PV-1.2-", "PV-2.5-", "PV-5-", "PV-8.7-" and "PV-15-", Voltage Transformers, manufactured by the Canadian General Electric Company Limited, Toronto 4, Ontario.

Rating of Apparatus:
Primary Voltages.

PV-1.2-	1200, 600, 480
PV-2.5-	2400.
PV-5-	4800, 4200, 2400, 600, 480.
PV-8.7-	7200, 4800.
PV-15-	14400, 12000, 8400, 7200, 4800.

Secondary Voltages
(all types)

120 and 120/120 single and double secondary or 115 and 115/115 but having the same ratios.

Accuracy Class.

PV-1.2-, PV-2.5-, PV-5- and PV-8.7-	0.3WXY; 0.6Z single secondary, 0.6WXY; 1.2Z double secondary.
PV-15-	0.3WXYZ single and double secondary.

Voltage Class

Kilovolt insulation class incorporated in type designation.

Wire

2

Frequency

60 cycles

Style

Dry Indoor.

*Approved Variations indicated by suffix to type designation

"A"	Unfused
"F"	Fused
"C"	High voltage terminal H ₂ grounded
"B"	Primary terminal position changed.

* All units covered by this approval will carry one or more of the above suffixes.

Description:

These transformers are designed for indoor service and have a single primary winding and a single or double secondary

100

100

100

100