

SPE-0001

B.C. EA 16.

SE-83-4-5

January 20, 1954.

3L-100-72-1
3L-100-732B

Ferranti-Packard Electric Limited,
St. Catharines, Ontario.

Attention: Mr. E.L. Mills,
Supervisor of Engineering
Instrument Transformers.

Dear Sirs:

Re: Special Approval - Four only Ferranti-Packard
Type "RU15" 15000 Volt, Outdoor, Compound
Filled Current Transformers.

This is to advise that Special Approval has been granted by
the Standards Branch, for use in Canada for billing purposes, to:

two Type "RU15" 1500/3000-5 ampere Current Transformers,
serial numbers 2-62454 and 2-62455 with accuracy ratings of
0.3% 0.1, 10.5, 10.9, 1(2x)0.9, 12.0 on both ratios. The
nameplates are marked "0.3% 0.1";

and
two Type "RU15" 1000/2000-5 ampere Current Transformers,
serial numbers 2-62456 and 2-62457 with accuracy ratings of
0.3% 0.1, 10.5, 10.9; 0.6% (2x) 0.9, 12.0 on the 1000-5 ratio
and 0.3% 0.1, 10.5, 10.9, 1(2x)0.9, 12.0 on the 2000-5 ratio.
The nameplates are marked "0.3% 0.1".

These four transformers are for the British Columbia Hydro
and Power Authority at Vancouver B.C. for installation at Quadra, B.C.
Test results with burden 5.9 were supplied with all units.

Yours very truly,

[Signature]
(for) E. P. Miller,
Chief, Electricity & Gas Division.

RJJ/lm

cc- Mr. Ward, Vancouver
cc- B.C. Hydro & Power Authority
(through Mr. Ward)

0011