SPE-0002

[illegible]-5
→ [illegible]-SPE-2
[illegible]-[illegible]

January 23, 1964.

Ferranti-Packard Electric Limited,
St. Catharines, Ontario.

Attention: Mr. [illegible] Mills,
Supervisor of Engineering
Instrument Transformers

Dear Sirs:

Re: Special Approval - Two only Ferranti-Packard Type "K69", 600/1200-5 ampere, 69 KV, 60 cycle, Outdoor, Oil Insulated Current Transformers.

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to two only Ferranti-Packard Type "K69" 600/1200-5 ampere, 69 kv, 60 cycle, Outdoor Oil Insulated Current Transformers, Serial Numbers 2-[illegible] and 2-[illegible], with metering accuracies as follows:

600 amperes - 0.3B0.1, B0.5, B0.9; 0.6S(2x0.9), B2.0.
1200 amperes - 0.3B0.1, B0.5, B0.9, B(2x0.9), B2.0.
The nameplate marking is 0.3 B0.9.

These transformers are for the West Kootenay Power and Light Company Limited for installation at [illegible] and test tags were supplied showing accuracies at burden B0.9.

Yours very truly,

(for) [illegible] Power,
Chief,
Electricity & Gas Division.

JRG/[illegible]

cc- Mr. A. L. Heaven, Penticton.

cc- West Kootenay P & L (through Mr. Heaven)