

→ 11-120-SPE-3
11-120-SPE-4

CPA 10.

January 23, 1944

Ferranti-Richard Electric Limited,
St. Catharines,
Ontario.

Attention: Mr. E. L. Hill
Supervisor of Engineering
Industries Department.

Dear Sirs:

Special Approval - Sixteen Ferranti-Richard
Type "35" 2700-115-115 volt, 60 cycle, out-
door oil insulated Voltage Transformers,
Serial numbers 2-5775 to 2-5772 inclusive.

This is to advise that Special Approval has been granted
by the Standards Branch for use in Canada for billing purposes to 16
Ferranti-Richard Type "35", 2700-115-115 volt, 60 cycle, outdoor
oil insulated Voltage Transformers with serial numbers 2-5775 to
2-5772 inclusive. Rating accuracy is 0.3% at 0.01 on one secondary
with the other secondary carrying the same burden simultaneously.
The maximum error is 0.6% - 1.0%. Test taps were supplied with
the units, shunting accuracies with 0 burden on each secondary and a
burden on each secondary.

These transformers are for the Hydro Electric Power
Commission of Ontario, Central Stores, Toronto, Ontario.

Yours very truly,

J.R.S.

(Sgt) E. L. Hill,
Chief,
Electricity & Gas Division.

J.R.S.

cc - Mr. E. L. Hill, Toronto

cc - Mr. J. C. O'Neil (through Mr. Hill)