

FD - 35

SPE-0006

T & C PH 16.

→ -29-2-7
IL-17-18-6
IL-180-39

File 1

WJZ

January 30, 1954.

Canadian Westinghouse Co. Ltd.,
P. O. Box 2220,
London, Ontario.

Attention: Mr. F. J. Holster, P. Eng.
Engineering Department
Distribution Apparatus Division

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to six only Type "P.T" Voltage Transformers for use by Hydro-Quebec in Metropolitan Montreal.

These transformers conform to the design specifications of Type "P.T", approved under Circular I-A-543, but are tested for insulation strength prescribed for 0.7 kv class. Serial numbers of the units are 43737 to 43744 inclusive. Accuracy class is 0.5% at 60 cycles.

Yours very truly,

J. R. L.
(for) H. J. Brown,
Chairman,
Electricity & Gas Division.

JAS/km

cc- Mr. Neysmith, Montreal
cc- Hydro Quebec (through Neysmith)