

RECORDS

MAR 11 1964

18 PA 16

F2 - 33

SP-0007

SE-35-4-5

SI-100-10-7

4-513-124

March 9, 1964.

Ferranti-Packard Electric Limited,
ST. CATERINES,
Ontario.

Attention: Mr. L. L. Mills,
Supervisor of Engineering
Instrument Transformers

Dear Sir:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to one only Type "05315", 400/800-5 ampere, 14400-120 volt, 60 cycle, 3 phase, 3 wire Outdoor Oil Insulated Metering Equipment, Serial number 2-04278.

This outfit is for the Saskatchewan Power Corporation at Regina, Saskatchewan, and contains:

- 2 Type "1015" 14400-120 volt, 60 cycle voltage transformers approved under Circular S-EL-506; and
- 2 Type "M" 400/800-5 ampere current transformers with metering accuracies of 0.300.1, 00.5, 00.9, 0(2 x 0.9) on 800 amperes and 0.300.1, 00.5, 00.9 and 0.00(2 x 0.9) on 400 amperes. The name-plate is marked "0.500.9".

Yours truly,

W. J. S. Fraser
(for) W. S. Fower,
Chief, Electricity and Gas Division,
Standards Branch.

JRC/mj

c.c. - Mr. W.E. Fletcher,
District Inspector (L&G), Regina, Sask.

c.c. - Saskatchewan Power Corporation through Mr. Fletcher.