

RECORDS

MAR 11 1964

F 2 - 33

SPF-0008

INCPA 16.

SE-25-4-5  
SI-100-311-5  
A-276-743

March 9, 1964.

Ferranti-Packard Electric Limited,  
St. Catharines,  
Ontario.

Attention: Mr. W. L. Mills,  
Supervisor of Engineering,  
Instrument Transformers

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to one only Type "K146", 27000/46000-115 volt, 100/200-5 ampere, 60 cycle, 3 phase, 3 Wire Outdoor Oil Insulated Metering Equipment, Serial Number 2-62772.

This outfit contains:

- 2 Type "K146" 100/200-5 ampere current transformers approved under Circular S-CA.427; and
- 2 Type "K146" 27000/46000-115 volt, 60 cycle voltage transformers with metering accuracies of 0.3 WY; 0.6% on 46000 volts and 0.3 WY; 0.6% on 27000 volts. The secondary winding is extended to provide 115 volts when the primary applied voltage is 27000.

This equipment is for the Hydro-Electric Power Commission of Ontario for installation at the Canada Electric Company at Brantford, Ontario.

Yours truly,

*W. J. S. Fraser*

(For) W. F. Power,  
Chief, Electricity and Gas Division,  
Standards Branch.

JRG/mj

c.c. - Mr. W.R. McEown,  
District Inspector (REG), Toronto, Ont.

c.c. - Hydro-Electric Power Commission of Ontario through Mr. McEown.