

RECORDS

F2 - 32
SPR 0009

MAR 22 1964

SP-55-1-5
SL-100-124.9
A-733

Ottawa, March 10th, 1964

T & C PA 16.

Forrenti-Packard Electric Limited,
St. Catharines, Ontario.

Attention: Mr. E. L. Mills,
Supervisor of Engineering
Instrument Transformers

Dear Sir:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to three Type "405", 1000/3000-3 ampere, 5000 volt, 60 cycle, Outdoor Compound Filled Current Transformers, Serial numbers 2-64225, 2-64226, 2-64227.

These transformers are for the Chatham Hydro Electric System at Chatham, Ontario. They have metering accuracies of 0.5% on 1000 amperes and 0.5% on 3000 amperes. Handplates are marked "0.5% 0.9".

Yours very truly,

W. J. S. Fraser

(for) H. F. Foster
Chief, Electricity & Gas Division
Standards Branch

JMS/cr

c.c. Mr. W. J. Henderson c/Dist. Inspector (REG) London, Ontario.

c.c. Chatham H.E.S. through Mr. Henderson